

**DATE June 9, 2015**

**ADDENDUM NO. 2  
to the  
Iowa Department of Transportation  
Proposal No. 14400  
For Fairfield Maintenance Facility new exterior wall and insulation  
Letting Date: June 17, 2015**

**Notice To Bidders:**

This Addendum is issued to incorporate the following additions, deletions, corrections, and/or clarifications to the terms or specifications and shall hereby be considered a part of the final contract documents. This Addendum shall supersede, modify and/or change all statements to the contrary in the bid proposal and shall take precedence over previous terms or specifications.

**Clarifications:**

1. Regarding the location of the reinforcing strands in the current precast concrete panels which need to be avoided in the installation of new structural steel angles: "A rebar locating instrument will need to be used to locate the reinforcing. Most geotechnical/material testing firms should have this type of equipment." per Structural Engineer.
2. Alternates will only be considered if they are lower cost than the base design.


All Bidders must sign and return this Addendum for the bid opportunity referenced above. Failure to do so may subject the Bidder to disqualification. If a bid response has already been submitted, this Addendum shall be signed and emailed or faxed to the Purchasing Section prior to the scheduled Letting Date.

\_\_\_\_\_  
Company Name *(please print)*

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature

Sincerely,



Rhonda Ruark, Purchasing Agent  
Phone No. 515-239-1285 Fax No. 515-239-1538  
[Rhonda.ruark@dot.iowa.gov](mailto:Rhonda.ruark@dot.iowa.gov)